



City of Elko Clerk's Department  
1751 College Avenue  
Elko, NV 89801  
(775) 777-7126  
FAX (775) 777-7129

**ADDENDUM NUMBER ONE**

**Ruby Vista Drive Curb and Gutter**

---

Please confirm receipt of ADDENDUM NUMBER ONE AND FAX BACK TO (775) 777-7129 or email to [cityclerk@elkocitynv.gov](mailto:cityclerk@elkocitynv.gov).

RECEIVED:

---

SIGNATURE

---

COMPANY NAME

Dated this 30<sup>th</sup> day of June, 2023.

Elko City Clerk

Kelly Wooldridge

**\*\*\* PLEASE NOTE RECEIPT OF ADDENDUM NUMBER ONE ON  
APPLICABLE LINE ON SUBMITTED BID PROPOSAL \*\*\***



CITY OF ELKO  
ENGINEERING DEPARTMENT  
1755 COLLEGE AVENUE  
ELKO, NEVADA 89801  
(775)777-7210  
(775)777-7219 FAX

**ADDENDUM #1**  
**Ruby Vista Drive Curb and Gutter Project**

**PWP# EL-2023-429**

**June 30, 2023**

This addendum addresses clarifications to the Contract Documents and Contract Drawings for the City of Elko Ruby Vista Drive Curb and Gutter project.

**CLARIFICATIONS:**

- 1 – The Engineer's estimate for this project is \$720,000.
- 2 – From Station 0+30 to Station 11+20, where the curb will be poured along the existing edge of asphalt, the flow line should maintain a steady grade, and the tilt of the gutter pan may vary to match minor variations in the grade of the existing asphalt.
- 3 – At station 34+50, the drawings call for grouted rip-rap. Bid Item 16 is the item for the rip-rap. The price for this bid item shall include the grout.

Please reach out to the City Clerk's office with any additional questions by July 10, 2023. Thanks you for your interest in this project.

Sincerely,

Bob Thibault, P.E., P.L.S.  
City of Elko  
Civil Engineer

